



# DECLARATION

## Declaration of Conformity



**Applicant:** **SolarEdge Technologies LTD**  
1 HaMada Street  
4673335 Herzeliya,  
Israel

**Product type:** Power Optimizer

**Model:** Pxxx, PxxxI  
OPJxxx-LV  
xxx can be a number from 0-9 showing the max. input power.

The power optimizers in combination with the SolarEdge inverters or SMI fulfill the requirements of the mentioned clauses of below standard.

**Standard:** **VDE-AR-E 2100-712:2018-12**

Measures for the DC range of a PV installation for the maintenance of safety in the case of firefighting or technical assistance

**§7.1 Means for switching, disconnecting or short-cutting the DC part of a PV installation**

**§7.4 Means for switching off PV-modules**

In order to show full compliance of a PV installation according to the aforementioned standard, the installer must ensure compliance according

**§5 Marking of the installation and PV DC wiring.**

**Report no:** 19KFS090-02

**Certificate no:** 19-174-00

**Date of issue:** 2019-11-20

**Kiwa Primara GmbH**  
Gewerbestraße 28  
87600 Kaufbeuren  
Germany  
Tel. +49 8341 99726-0  
info@primara.net  
www.kiwa.de

**Samuel Thiboutot Rioux**