

CERTIFICATE of Conformity



Registration No.: AK 50496160 0001

Report No.: CN2119YA 001


Holder: SolaX Power Network Technology
(Zhejiang) Co., Ltd.
No.288 Shizhu Road
Tonglu Economic Development Zone
Tonglu City,
Zhejiang Province 310000
P.R. China

Product: PV-Inverter
(Grid Tied Inverter With Storage System)

Identification: Type Designation : X1-Hybrid-x-y X1-Fit-x-z
(x=3.0, 3.7, 5.0, 6.0, 7.5;
y=D or M; z=M or W)
Serial Number : Engineering samples
Firmware Version : Master DSP: 2.07, Slave DSP: 2.01,
ARM:2.03
Remark(s) : Refer to report CN2119YA 001 for details.
Power limits depend on national deviation

Tested acc. to: EN 50549-1:2019

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 02.03.2021


Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

SolaX Power Network Technology (Zhejiang) Co., Ltd.
Jason Shen

Date : 02.03.2021
Our ref. : PJG 01
Your ref.: Jason Shen

No.288 Shizhu Road
Tonglu Economic Development Zone
Tonglu City,
Zhejiang Province 310000
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid Tied Inverter With Storage System
Model Designation : See Certificate
Certificate No. : AK 50496160 0001
Report No. : CN2119YA 001

Dear Jason Shen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

CC: SolaX Power Network Technology

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询